

Hampton Green Energy Committee
Hampton, CT 06247
Meeting Minutes
Wednesday, June 12 , 2019
7:00 PM
Town Hall Conference Room

Chair Kate Donnelly and Maryellen Donnelly attended. The meeting was not held.

Of note is the solar system data to have been reported.

There continues to be no online report of the Shippee monitor for the Town Hall ground mount system.

Only a daily report is available online for the Shippee 9 kW system on Hampton Elementary School.

The kilowatt hour production of the Hampton Elementary School 127.75 kW system to date is 294,172 kWh.
The monthly production is as follows.

2018	kWh	2019	kWh
January	3,067.42	January	6,752.87
February	4,848.27	February	7,875.31
March	4,328.11	March	9,615.21
April	9,414.68	April	10,629.28
May	16,455.24	May	13,386.62
June	18,022.09	June 1-11	6856.52
July	17,723.88		
August	15,353.24		
September	10,765.24		
October	8,613.04		
November	5,508.66		
December	7,906.74		

Respectfully submitted,

Maryellen Donnelly